



CAPE ENVIRONMENTAL LABORATORY, L.L.C.

102 North Main • Cape May Court House, NJ 08210

email address: capelab2@gmail.com

Phone: 609-463-0077

Fax: 609-463-8977

D.E.P. Cert. #05679

Client: Principle Academy Charter School

Address: 6718 Blackhorse Pike # 16

LEAD

Analyzed by: Jason Delp

Analyzed Date: 5/26/22

Analyzed Time: 3:04 PM

Analysis Method: SM-3113B

COPPER

Analyzed by: Jason Delp

Analyzed Date: 5/31/22

Analyzed Time: 12:56 PM

Analysis Method: SM-3113B

<u>Field Sampled ID #</u>	<u>Sample #:</u>	<u>Sample Location</u>	<u>Sample Date:</u>	<u>Sample Time</u>	<u>Sample Received:</u>	<u>Sampled By:</u>	<u>Lead Result(ug/L)</u>	<u>Copper Result(mg/L)</u>	<u>Action</u>	<u>Action</u>
									<u>Level (ug/L)- Lead</u>	<u>Level (mg/L)- Copper</u>
66142	1	Board Room	5/22/22	8:17 AM	5/22/22	Client	<2.0	0.146	15	1.3
	2	Nurses's Office	5/22/22	8:19 AM	5/22/22	Client	<2.0	0.138	15	1.3
	3	Bottle Fill(nearest 3rd)	5/22/22	8:20 AM	5/22/22	Client	<2.0	0.108	15	1.3
	4	Bottle Fill(nearest CST)	5/22/22	8:20 AM	5/22/22	Client	<2.0	0.111	15	1.3
	5	Janitor's closet	5/22/22	8:21 AM	5/22/22	Client	<2.0	0.186	15	1.3
	6	Kitchen (nearest inside)	5/22/22	8:22 AM	5/22/22	Client	3.34	0.086	15	1.3
	7	Kitchen (nearest outside)	5/22/22	8:23 AM	5/22/22	Client	4.25	0.064	15	1.3
	8	KGA-127	5/22/22	8:25 AM	5/22/22	Client	2.78	0.059	15	1.3
	9	1A-129	5/22/22	8:26 AM	5/22/22	Client	<2.0	0.058	15	1.3
	10	1B-131	5/22/22	8:27 AM	5/22/22	Client	<2.0	0.065	15	1.3
	11	1C-133	5/22/22	8:28 AM	5/22/22	Client	<2.0	0.058	15	1.3

Tim Delp, Lab Director